Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-16-06**

Date: 07/02/2018

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Construction of CC roads and drains 1st Main road from 3rd Cross to Dead end at Attur layout in Ward No.03

Agency : Sri.G. Venkate Gowda, No.53/1, 14th "A" Cross, "A" Sector , New Town, Yelahanka, Upanagara, Banglore-64

Customer's Reference : EE(Project)/YnkZone/WO/115/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 16-01-18

Sample ID No : 2018-01-16-06/04

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 07/02/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	10/01/2018	07/02/2018	150.32 X 150.29 X 150.30	22592	8.249	476.7	21.1	20.7
2	Drain Concrete	M20	10/01/2018	07/02/2018	150.36 X 150.34 X 150.31	22605	8.297	467.9	20.7	
3	Drain Concrete	M20	10/01/2018	07/02/2018	150.25 X 150.27 X 150.20	22578	8.245	460.6	20.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-16-06** **Date: 17/01/2018**

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Construction of CC roads and drains 1st Main road from 3rd Cross to Dead end at Attur layout in Ward No.03

Agency : Sri.G. Venkate Gowda, No.53/1, 14th "A" Cross, "A" Sector , New Town, Yelahanka, Upanagara, Banglore-64

Customer's Reference : EE(Project)/YnkZone/WO/115/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 16-01-18

Sample ID No : 2018-01-16-06/01

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 16/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	09/01/2018	16/01/2018	150.25 X 150.29 X 150.21	22581	8.266	388.4	17.2	17.5
2	Drain Concrete	M20	09/01/2018	16/01/2018	150.24 X 150.22 X 150.34	22569	8.287	395.0	17.5	
3	Drain Concrete	M20	09/01/2018	16/01/2018	150.24 X 150.29 X 150.33	22580	8.289	404.2	17.9	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

****End of Report****

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-01-16-06**

Date: 06/02/2018

Customer : Assistant Executive Engineer, Project Sub Division, BBMP, Bangalore.

Address : Project Sub Division, BBMP, Bangalore.

Project Name : Construction of CC roads and drains 1st Main road from 3rd Cross to Dead end at Attur layout in Ward No.03

Agency : Sri.G. Venkate Gowda, No.53/1, 14th "A" Cross, "A" Sector , New Town, Yelahanka, Upanagara, Banglore-64

Customer's Reference : EE(Project)/YnkZone/WO/115/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 16-01-18

Sample ID No : 2018-01-16-06/02

Customer ID : Drain Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M20 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 06/02/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	09/01/2018	06/02/2018	150.42 X 150.34 X 150.36	22614	8.287	470.4	20.8	20.9
2	Drain Concrete	M20	09/01/2018	06/02/2018	150.29 X 150.25 X 150.22	22581	8.294	481.0	21.3	
3	Drain Concrete	M20	09/01/2018	06/02/2018	150.32 X 150.34 X 150.36	22599	8.276	463.3	20.5	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |